



Project ID: 2024-03-0101

Project Name: Procurement of Industrial Generator

Project Location: ATI-RTC I, Tebag East, Sta. Barbara, Pangasinan

BID BULLETIN NO. 1

April 4, 2024

Subject: Minimum Requirements

This Bid Bulletin No. 1 is issued to amend/supplemental provisions in the Bidding Documents (BDs) for the above stated Project, as follow;

Current Provisions of BDs (including Previous Amendments);

1. Section VII Technical Specifications

Item Number	Description	Quantity	Unit	Statement of Compliance
1	Industrial Generator 60 KVA, with Installation	<i>1</i>	Unit	

Amended Provision of BDs under this Bid Bulletin;

1.1 Section VI Technical Specifications

Item Number	Description	Quantity	Unit	Statement of Compliance
1	Minimum Requirements 1. Installation of Generator set with the following: <ul style="list-style-type: none">60KVA, 230V, 3-phase, 60hz, 80%PF, Silent type Generator Set (Connected to existing MCB and with appropriate earth grounding)	<i>1</i>	Unit	

	<ul style="list-style-type: none"> • Appropriate Machine Pad for the genset • Entrance Wires in conduits with appropriate concrete jacket, provide entrance caps when necessary • Automatic Transfer Switch, 150A • At least 1 year warranty • Shelter (optional) <p>2. Specify existing after sales service center</p>		
--	--	--	--

This supplemental Bulletin shall form an integral part of the said Bidding Documents.

For the guidance and information of all concerned.





GRACE T. VENTURA, Ph.D.
BAC Chairperson